

Norwood Water Commission

Public Works Report

July 2024

- All samples including TTHM and HAA5s came back good
- We have been doing rigorous flushing throughout the system
- We have started on the security camera project. We dug the trench; the electrician and Jason will have their end of project finished by the end of the month
- Farmers water thinks the ditch with go off some time around the 20th (we will top off the reservoir again)
- Our Redvale project has begun. HDPE pipe is oddly hard to find right now. Riley was able to get 20' sections found, it will be a little more work on his end of things but will still be faster and cheaper than getting continuous rolls delivered to our area in a timely manner.
- I am waiting for a cost proposal from filter tech to have the media in #3 filter vacuumed out and replaced.
- We have been treating the reservoir for algae
- We have begun the lead line inventory for the state, I hope to have it finished up by the end of August
- I was able to get my Distribution class 3 certification. (so if the state should up our classification like they were discussing we will be covered)
- I am also working towards getting my Water Treatment Class A certification